WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78964
Permit No. 10999
Basin 162

NOTICE OF INTENT NO. 19064

1. OWNER Joe Sladek
MAILING ADDRESS 2250 S. Hwy 160 Pahrump, NV 89048
ADDRESS AT WELL LOCATION 2250 S. Hwy 160 Pahrump

2. LOCATION SE ¼ NW ¼ Sec. 30 T. 20S N/S R. 54 E. Nye County
PERMIT NO. 10999 Issued by Water Resources | 42-391-09 Parcel No. | Calvada Valley Unit 1 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
First inspection found a 16" double wall thickness irrigation well. Required 2 drilling logs one dated 2/28/49 showing a 16" 496' well cased with stovepipe to 252'. permit# 10999 permit# 14106 well deepened 15 7/8" hole from 252' to 1076' cased with taper from 12" to 10" from 242 to 368', 10" casing from 374' to 1076' Casing perforated from 302' to 1070' (from log dated 4/21/52) Casing was perforated from 252' to 300' with cable rig using 6 linear cuts 20' long approximated 1' apart After perforation completed 40 yds of 9 sack cement grout was pumped by way of tremie pipe to the surface.				

DCNR/DWR Received DEC 1999 LAS VEGAS OFFICE

Date started November 9, 19 99
Date completed November 12, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 98 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ron Naillon Drilling Contractor
Address Box 265 Pahrump, NV 89041 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0035704
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest LaRue
By driller performing actual drilling on site or contractor
Date November 18, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627