WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 18970
Permit No.
Basin 87

NOTICE OF INTENT NO. 39853

OWNER Alan Duvall
MAILING ADDRESS 1195 Reese Way
Reno, NV 89511

ADDRESS AT WELL LOCATION 1195 Reese Way

2. LOCATION NE 1/4 NW 1/4 Sec. 34 T 18N N/S R 20E E Washoe County
PERMIT NO. WaCo#6478 (Issued by Water Resources) 17-451-04 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the 6 5/8" x 126' deep domestic water well. We perforated from approximately 107' to approximately 48' where we hit the cement seal. We perforted 4 perforations at each foot at 90 degrees to each other. We pumped approximately 1.3 cu. yards of neat cement mixed at 5.2 gal. water per 94 lb. sack of cement. We used tremie pipe and pumped from the bottom to the top. We cut the casing off at ground level.				

Date started 12/21/1999, 19__
Date completed 12/21/1999, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 126 Feet Depth Cased 126 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12.92	.188	0	126

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 48' feet to 107' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 12/21/99

USE ADDITIONAL SHEETS IF NECESSARY