

OFFICE USE ONLY  
 Log No. 79015  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37056

1. OWNER DAVE MILLS ADDRESS AT WELL LOCATION SAH  
 MAILING ADDRESS BEACON FOOD MART  
103 Hwy Hunter N.V.  
 2. LOCATION SE 1/4 SW 1/4 Sec 29 T 13 N/S R 20 E County TOYAHvale  
 PERMIT NO. 25-180-090 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Other SPACE POINT  
 Deepen  Abandon

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG SAH 7

Material	Water Strata	From	To	Thick-ness
<u>CLAY Cobble</u>		<u>0</u>	<u>11</u>	<u>11</u>
<u>GRAVELY CLAY</u>	<u>12</u>	<u>11</u>	<u>23</u>	<u>12</u>
<u>GRAVELY SAND</u>		<u>23</u>	<u>30</u>	<u>7</u>

8. WELL CONSTRUCTION  
 Depth Drilled 30 Feet Depth Cased 30 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Inches To 30 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1</u>	<u>PVC</u>	<u>SAH 40</u>	<u>0</u>	<u>30</u>

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal N/A 26'  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
Bentonite

Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 30 feet to 26 feet

9. WATER LEVEL  
 Static water level 1 1/2 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature N/A °F Quality N/A

Date started 2-5, 1997  
 Date completed 2-5, 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ANDREW DRILLING Contractor  
 Address 1635 BELFORT RD  
RENO, N.V. 89509  
 Nevada contractor's license number 3458 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M10787-1  
 Signed Andrew Drilling  
 By driller performing actual drilling on site or contractor  
 Date 2-16-97