WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79047
Permit No.
Basin 54
NOTICE OF INTENT NO. 39122

1. OWNER CECIEL LYPE
MAILING ADDRESS HC 66 BOX 27
BEOWAWE, NV 898821

ADDRESS AT WELL LOCATION
HIGHWAY 306

2. LOCATION SW 1/4 NE 1/4 Sec. 33 T 29 N/S R 48 E EUREKA County
PERMIT NO. _____ Issued by Water Resources | 0547043 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| LOAM | | 0 | 3 | 3 |
| HARDPAN | | 3 | 15 | 12 |
| GRAVEL AND SAND | X | 15 | 16 | 1 |
| SANDSTONE | | 16 | 74 | 58 |
| GRAVEL | X | 74 | 100 | 26 |

RECEIVED
00 JAN -6 AM 11:54
STATE ENGINEER'S OFFICE

Date started 11/9/99, 19__
Date completed 11/12/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 80 | | 3.5 |

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10/5/8 Inches | | 0 Feet | 100 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | 188 | +2 | 100 |

Perforations:
Type perforation MILL SLOT
Size perforation 3/16" X 3" SLOT
From 80 feet to 100 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 51
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 51 feet to 100 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COLD °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fertig Drilling Company (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 12-1-99