~~PPW-8~~ PPW-98

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79048
Permit No.
Basin 61

NOTICE OF INTENT NO. 42875

1. OWNER Barrick Goldstrike
MAILING ADDRESS P.O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike
Minesite, North of Carlin, NV

2. LOCATION SW ¼ SE ¼ Sec. 19 T. 36 (N)S R. 50 E. Eureka County
PERMIT NO. ~~N/A~~ 55140 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granodiorite		0	380	380
Black Vanini		380	390	10
Grey Clay		390	410	20
Granodiorite		410	550	140
Black Vanini		550	585	35
Granodiorite		585	600	15
Black Vanini		600	645	45
Granodiorite		645	660	15
*Note:				
Hole Plug		50	130	80

Date started 25 August, 19 99
Date completed 2 September, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 660 Feet Depth Cased 650 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
19 Inches		0 Feet	40 Feet
12.45 Inches		40 Feet	660 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14.0	54.57	.375	0	40
6.625	17.02	.250	+1	650

Perforations:
Type perforation Louvered
Size perforation 0.125"
From 150 feet to 650 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
*See note at left
Gravel Packed: ☒ Yes ☐ No
From 130 feet to 660 feet

9. WATER LEVEL
Static water level 366' 4" feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature 80 °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1716-T1
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2 September, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

BST-C