

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 779 79110
 Permit No. 1
 Basin. CI

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43224

1. OWNER Barrick Goldstrike
 MAILING ADDRESS P.O. Box 29
Elko, NV 89803
 ADDRESS AT WELL LOCATION Barrick Goldstrike
Minesite, North of Carlin, NV

2. LOCATION SW $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 19 T. 36 NS R. 50 E. Eureka County
 PERMIT NO. N/A Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandoned by pumping neat cement from T.D. to surface				
Used 15 cu.ft. of cement				
1: 7 cu.ft.				
2: 4.25 cu.ft.				
3: 3.75 cu.ft.				
Construction Detail				
Cement		0	50	
Hole Plug		50	312	
Gravel Pack		312	330	
Hole Plug		330	388	
Gravel Pack		388	405	
Hole Plug		405	635	
Gravel Pack		635	655	

8. WELL CONSTRUCTION
 Depth Drilled 655 Feet Depth Cased 650 Feet
 HOLE DIAMETER (BIT SIZE)
 From 14.75 Inches 0 Feet 55 Feet
 To 8.250 Inches 55 Feet 655 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.750	34.24	0.250	+2	55
1:1.66	2.27	0.140	+1	650
2:1.66	2.27	0.140	+1	400
3:1.66	2.27	0.140	+1	325

Perforations: Drilled Holes
 Type perforation _____
 Size perforation 0.187"
 From 1: 645 feet to 650 feet
 From 2: 395 feet to 400 feet
 From 3: 320 feet to 325 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No See Detail
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level All tubes dry feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 31 August 1999
 Date completed 31 August 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2085
 Signed Daniel Kohlman
 By driller performing actual drilling on site or contractor
 Date _____