

DIVISION OF WATER RESOURCES

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
Log No. 79112  
Permit No. \_\_\_\_\_  
Basin 61  
NOTICE OF INTENT NO. 43225

1. OWNER Barrick Goldstrike  
MAILING ADDRESS P.O. Box 29  
Elko, NV 89803  
ADDRESS AT WELL LOCATION Barrick Goldstrike  
Minesite, North of Carlin, NV

2. LOCATION SW 1/4 SE 1/4 Sec. 19 T. 36 N. S. R. 50 E. Eureka County  
PERMIT NO. N/A Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandoned by pumping neat cement from T.D. to surface				
Used 20.25 cu.ft. cement				
1: 8.75				
2: 6.0				
3: 5.5				
Construction Detail				
Cement		0	50	
Hole Plug		50	185	
Gravel Pack		185	200	
Hole Plug		200	265	
Gravel Pack		265	280	
Hole Plug		280	400	
Gravel Pack		400	420	

8. WELL CONSTRUCTION  
Depth Drilled 420 Feet Depth Cased 410 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 Feet To 35 Feet  
14.75 Inches  
8.0 Inches 35 Feet 420 Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.750	34.24	0.250	+1	35
1: 1.66	2.27	0.140	+1	410
2: 1.66	2.27	0.140	+1	275
3: 1.66	2.27	0.140	+1	196

Perforations: Drilled Holes  
Type perforation \_\_\_\_\_  
Size perforation 0.187"  
From 1: 405 feet to 410 feet  
From 2: 270 feet to 275 feet  
From 3: 191 feet to 196 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No See Detail  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level: All tubes dry feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Lang Exploratory Drilling Contractor  
Address P.O. Box 5279 Contractor  
Elko, NV 89802  
Nevada contractor's license number issued by the State Contractor's Board: 0021976  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 2085  
Signed \_\_\_\_\_  
By driller performing actual drilling on site or contractor  
Date \_\_\_\_\_

Date started 31 August 1999  
Date completed 31 August 1999

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

RECEIVED  
SEP - 8 11:43  
STATE ENGINEERING OFFICE

B.S.T. 1