

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 79141  
Permit No. 614  
Basin. 43231

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43231

1. OWNER BARRICK GOLDSTRIKE  
MAILING ADDRESS P.O. BOX 29  
ELKO, NV 89803  
ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINESITE, NORTH OF CARLIN, NV.

2. LOCATION NW 1/4 NE 1/4 Sec. 30 T. 36 N/S R. 50 E EUREKA County  
PERMIT NO. N/A Issued by Water Resources  
N/A Parcel No.  
N/A Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GRAY ROCK		0	30	30
GRAY CLAY		30	50	20
GRAY AND BLACK ROCK		50	110	60
GRAY AND BLACK ROCK WITH GRAY CLAY		110	125	15
GRAY AND BLACK ROCK		125	230	105
GRAY AND BLACK ROCK WITH GRAY CLAY		230	240	10
GRAY AND BLACK ROCK		240	440	200
GRAY AND BLACK ROCK WITH GRAY CLAY		440	580	140

8. WELL CONSTRUCTION  
Depth Drilled 580 Feet Depth Cased 559 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
14.75 Inches 0 Feet 29 Feet  
8.25 Inches 29 Feet 580 Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10.75</u>	<u>40.48</u>	<u>0.365</u>	<u>0</u>	<u>28.75</u>
<u>1: 2.375</u>	<u>3.65</u>	<u>0.154</u>	<u>+1</u>	<u>559</u>
<u>2: 2.375</u>	<u>3.65</u>	<u>0.154</u>	<u>+1</u>	<u>459</u>

Perforations:  
Type perforation SLOTTED  
Size perforation 0.125"  
From 1: 519 feet to 559 feet  
From 2: 419 feet to 459 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No SEE DETAIL  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. 1: 418.6 WATER LEVEL 2: 368.6  
Static water level \_\_\_\_\_ feet below land surface  
Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature COOL °F Quality FAIR

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name LANG EXPLORATORY DRILLING Contractor  
Address P.O. BOX 5279 Contractor  
ELKO, NV 89802  
Nevada contractor's license number issued by the State Contractor's Board 0021976  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1716-T1  
Signed Alan Beaudoin  
By driller performing actual drilling on site or contractor  
Date SEPTEMBER 30, 1999

Date started SEPTEMBER 19, 1999  
Date completed SEPTEMBER 26, 1999

7. WELL TEST DATA

TEST METHOD	<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	Draw Down (Feet Below Static)	Time (Hours)
<u>G.P.M.</u>			