WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79176
Permit No.
Basin 92B

NOTICE OF INTENT NO. 38059A

1. OWNER Care Chest c/o Bill Kahl
MAILING ADDRESS 5390 Riggins Court
Reno, NV 89509

ADDRESS AT WELL LOCATION ~~7510 N. Virginia St.~~
Reno, NV 89506

2. LOCATION SW 1/4 NW 1/4 Sec. 15 T 20N N/S R 19E E Washoe County
PERMIT NO. WaCo#6537 Issued by Water Resources | 082-290-17 Parcel No. | Subdivision Name

3. **WORK PERFORMED**
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thick-ness
On this date we pulled the pump from the well. We measured depth at 224'. There was no water in the well and Matt Dillon said that we could fill without additional perforations. We poured approximately 1.75 yards of 6 sack sand grout down the well and filled to top. According to static water level at other well on property, the water table would have been about 290. Therefore, the water was about 65' below bottom of well.				

Date started 02/25/2000 , 19__
Date completed 02/25/2000 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled ____ Feet Depth Cased 224 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	.188	12.92	+1	224

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. **WATER LEVEL**
Static water level None feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 02/26/2000

USE ADDITIONAL SHEETS IF NECESSARY