WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79193
Permit No.
Basin 92B

NOTICE OF INTENT NO. 43885

1. OWNER LINDA REICHLIN
MAILING ADDRESS 15650 Toll Road
Reno, Nevada 89511

ADDRESS AT WELL LOCATION 9360 North Virginia Street
Reno, Nevada 89506

2. LOCATION NE ¼ NW ¼ Sec. 16 T. 20N N/S R. 19E E. Washoe County
PERMIT NO. (Issued by Water Resources) 082-650-19 (Parcel No.) Black Springs Area (Subdivision Name)

3. WORK PERFORMED
[X] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Replacement well for existing plugged well				
Top soil		0	1	1
Brown clay, gravels, some boulders		1	17	16
Brown clay with gravels		17	27	10
Rusty brown clay		27	35	8
Brown clay with gravels		35	53	18
Sticky brown clay		53	59	6
Brown clay with gravels		59	106	47
Cemented gravels, soft		106	116	10
Brown clay with gravels		116	146	30
Brown sandy clay with gravels		146	216	70
Brown clay with granite sands		216	296	80
Brown sandy vlay with volcanic & granite gravles		296	380	84
Soft zone (app 3 GPM)	X	380	384	4
Green weathered granite		384	405	21
Fractured granite	X	405	417	12
Green weathered granite		417	420	3
Fracture granite	X ?	420	428	8
Green weathered granite		428	450	22

Date started February 9, 2000, ~~19~~XX
Date completed February 11, 2000, ~~19~~XX

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		

8. WELL CONSTRUCTION
Depth Drilled 450 Feet Depth Cased 450 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	100 Feet
8 5/8 Inches	100 Feet	450 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	450

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 384 feet to 444 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100 feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 450 feet

9. WATER LEVEL
Static water level 186 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908 & 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date February 14, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627