WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79260
Permit No.
Basin 162

NOTICE OF INTENT NO. 20156

1. OWNER WAYNE WALLACE
MAILING ADDRESS
ADDRESS AT WELL LOCATION 10411 S. VICKI ANN

2. LOCATION SW ¼ NW ¼ Sec. 1 T. 22-S N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) 41-381-01 (Parcel No.) CALVADA VALLEY, UT:14, BK:23 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE		0	4	4
SANDY LOAM		4	8	4
TAN CLAY/LIMESTONE		8	26	18
TAN CLAY		26	42	16
CEMENTED GRAVEL		42	44	2
TAN CLAY/CALICHE		44	92	48
CEMENTED GRAVEL		92	96	4
TAN CLAY	X	96	135	39
CEMENTED GRAVEL		135	138	3
TAN CLAY		138	158	20
CEMENTED GRAVEL	X	158	160	2
GREEN CLAY		160	180	20
CEMENTED GRAVEL		180	183	3
GREEN CLAY	X	183	200	17

MAR 20 2000

Date started MARCH 15, 2000
Date completed MARCH 15, 2000

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	200

Perforations:
Type perforation TORCH CUT
Size perforation ¼" WIDTH 8" LONG
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JIM PIKE WELL DRILLING, LLC (Contractor)
Address P.O. BOX 56 (Contractor)
PAHRUMP, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 17563A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
Signed (By driller performing actual drilling on site or contractor)
Date MARCH 20, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627