WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79294
Permit No.
Basin 162

NOTICE OF INTENT NO. 20218

1. OWNER Richard Hargis
MAILING ADDRESS 860 W. Fairbanks
Pahrump, NV 89048

ADDRESS AT WELL LOCATION 860 W. Fairbanks
Pahrump, NV 89048

2. LOCATION SW ¼ SW ¼ Sec. 9 T. 21 N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 35-182-32 (Parcel No.) CalVegas Ranchos, U/D, Lot 76 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Surface | | 0 | 4 | 4 |
| Grey clay | | 4 | 18 | 14 |
| Soft brown clay | | 18 | 52 | 34 |
| Hard drilling clay | | 52 | 60 | 8 |
| Soft brown clay | x | 60 | 96 | 36 |
| Hard drilling clay | | 96 | 110 | 14 |
| Brown clay | x | 110 | 140 | 30 |

Date started 4-11-00, 19
Date completed 4-12-00, 19

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | -0- | 15 min |

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12 Inches | | 0 Feet | 140 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8" | 17# | .188 | 0 | 140 |

Perforations:
Type perforation Torch cut
Size perforation ½" wide x 8" long
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg Well Drilling (Contractor)
Address 1060 W. Basin Rd. (Contractor)
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725

Signed Charles Nyberg by CSO
(By driller performing actual drilling on site or contractor)
Date 4-17-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627