WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79334
Permit No.
Basin 162

NOTICE OF INTENT NO. 19080

1. OWNER Pete Brown
MAILING ADDRESS 2861 S. Homestead Rd. Pahrump, NV 89048
ADDRESS AT WELL LOCATION 3471 S. Mallard Ave. Pahrump, Nevada

2. LOCATION SE ¼ NE ¼ Sec. 36 T. 20 S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 41-064-02 (Parcel No.) Calvada Valley Unit 4B (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt		0'	20'	20'
white clay		20'	30'	10'
caliche		30'	35'	5'
brown clay		35'	50'	15'
caliche		50'	60'	10'
white clay		60'	80'	20'
caliche		80'	85'	5'
brown clay		85'	100'	15'
caliche		100'	110'	10'
brown clay		110'	125'	15'
white clay		125'	160'	35'

APR 28 2000

Date started March 22, 2000
Date completed March 28, 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	160 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.314	0'	140'

Perforations:
Type perforation Saw cut
Size perforation 1/8" x 3"
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 160 feet

9. WATER LEVEL
Static water level 68 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LaRue Construction Company (Contractor)
Address 4191 S. Jackie St. Pahrump, Nevada 89048 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0049225
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forrest LaRue (By driller performing actual drilling on site or contractor)
Date April 20, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627