WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79385
Permit No. 20546
Basin 212
T9490
NOTICE OF INTENT NO. ~~B~~

1. OWNER Dick & LaRue Worthen
MAILING ADDRESS 125 Worthen Circle
Las Vegas, Nev.

ADDRESS AT WELL LOCATION
Vacant 3801 GOWAN RD

2. LOCATION NE ¼ SW ¼ Sec. 7 T 20S N/S R 62 E Clark County
PERMIT NO. 20546 (Issued by Water Resources) 140-07-301-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Information from old log				
April 13, 1963 Log # 7121				
Pull Line Shaft Turbine				
Perferate 10" & 8" Pipe				
300 Ft. 10" Pipe				
350 Ft. 8" Pipe				
Cement from Bottom up				
with neat cement				

MAY 12

Date started 4/21/2000, 19
Date completed 4/22/2000, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10	0	.250	+1	304
8"	14.14	.156	390	655

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 66 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 Bonita Vista (Contractor)
Las Vegas, Nev. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552M
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 4-24-2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627