

OFFICE USE ONLY
 Log No. 79437
 Permit No. _____
 Basin. 22

 19680

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____
 Las Vegas Valley Water District

1. OWNER City of Las Vegas Water ADDRESS AT WELL LOCATION Las Vegas Valley Water District
 MAILING ADDRESS 3617 N. 5th Street 6005 E. Vegas Valley Dr.
N. Las Vegas, NV 89032 Las Vegas, NV 89122

2. LOCATION S SW 10 21 N/S R 62 E Clark County
 PERMIT NO. DW1113 161-10-401-003
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other Dewater

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------------------|--------------|------|-----|------------|
| 25-Dewater wells | | | | |
| Well #17, 18 & 19 | | | | |
| Silty | | 0' | 5' | 5' |
| Silty clay | | 5' | 30' | 25' |
| Well #16, 20, 21, 22 & 23 | | | | |
| Silty | | 0' | 5' | 5' |
| Silty clay | | 5' | 40' | 35' |

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

| Inches | Feet | From | To |
|--------|------|------|-----|
| 24" | 0' | 0' | 30' |
| 24" | 0' | 0' | 40' |

CASING SCHEDULE


| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 14" | 36.71 | 1.250 | 0 | 30' |
| 16" | 36.71 | 1.250 | 0 | 40' |

Perforations:
 Type perforation Machine
 Size perforation 1/4" x 2 1/2" x 3 rows @ 13
 From 10' feet to 30' feet
 From 20' feet to 40' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 0 feet to 50-40' feet



Date started 5/4/00
 Date completed 5/4/00

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |

9. WATER LEVEL

Static water level 5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.



Name ALLEN DRILLING INC Contractor
 Address 4847 S. VALLEY VIEW
LAS VEGAS, NV 89103
 Nevada contractor's license number 18917
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS2161

Signed David
 By driller performing actual drilling on site or contractor
 Date 5/16/00



Las Vegas Valley Water District
APN# 161-10-003
6005 E. Vegas Valley Dr.
Las Vegas, NV 89122

INTENT#19680
PERMIT # DW1113



14-30' Dewater wells
11-40' Dewater wells

