

OFFICE USE ONLY
 Log No. 79442
 Permit No. _____
 Basin 22



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19680
Las Vegas Valley Water District

1. OWNER City of Las Vegas Water ADDRESS AT WELL LOCATION Las Vegas Valley Water District
 MAILING ADDRESS 3617 N. 5th Street 6005 E. Vegas Valley Dr.
N. Las Vegas, NV 89032 Las Vegas, NV 89122

2. LOCATION S SW 10 21 N/S R. 62 E. Clark County
 PERMIT NO. DW1113 161-10-401-003 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other Disposal

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
25-Dewater wells				
Well #17, 18 & 19				
Silty		0'	5'	5'
Silty clay		5'	30'	25'
Well #16, 20, 21, 22 & 23				
Silty		0'	5'	5'
Silty clay		5'	40'	35'

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

From	To
24" Inches	0' Feet 30' Feet
24" Inches	0' Feet 40' Feet
Inches	Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14"	36.71	1.250	0	30'
16"	36.71	1.250	0	40'

Perforations:


Type perforation Machine
 Size perforation 1/4" x 2 1/2" x 3 rows @ 13

From 10' feet to 30' feet
 From 20' feet to 40' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Concrete Grout

Gravel Packed: Yes No
 From 0 feet to 30-40' feet



Date started 5/4/00 2000
 Date completed 5/4/00 2000

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN DRILLING INC Contractor
 Address 4847 S. VALLEY VIEW LAS VEGAS, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board 18917
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS2161

Signed David [Signature]
 By driller performing actual drilling on site or contractor
 Date 5/16/00

