

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43864

1. OWNER SCOTT & SHELLY BAKER ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 7900 No. Virginia Street 6210 Matterhorn Blvd.
Reno, Nevada 89506 Reno, Nevada 89506
 2. LOCATION SE 1/4 NE 1/4 Sec. 34 T22N R19E Washoe County
 PERMIT NO. 079-440-13 Antelope Valley Red Rock Est. #318
 Issued by Water Resources Parcel No. Subdivision Name part C

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
Decomposed granite		2	16	14
Rusty brown clay		16	18	2
Decomposed granite		18	69	51
Weathered granite		69	118	49
Rusty weathered granite		118	132	14
Weathered granite		132	249	117
Hard weathered granite		249	329	80
Rusty clay (soft)		329	330	1
Weathered granite		330	415	85
Soft zone clay		415	418	3
Weathered granite		418	535	117
Fracture (app 8 GPM)	X	535	536	1
Weathered granite		536	595	59
Fracture (app 7 GPM)	X	595	597	2
Weathered granite		597	625	28

8. WELL CONSTRUCTION
 Depth Drilled 625 Feet Depth Cased 625 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 625 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>625</u>

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 520 feet to 540 feet
 From 560 feet to 580 feet
 From 600 feet to 620 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 feet Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 625 feet

9. WATER LEVEL
 Static water level 432 feet below land surface
 Artesian flow _____ G.P.M. 15 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 0022549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller
 Signed Wayne Fedema
 By driller performing actual drilling on site or contractor
 Date May 1, 2000

Date started April 24, 2000
 Date completed April 27, 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>		

RECEIVED
 COUNTY OF WASHOE
 STATE ENGINEER'S OFFICE