

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT 40770

1. OWNER Ren Giacomo
 MAILING ADDRESS _____
 ADDRESS AT WELL LOCATION 9th St, Silver Springs, Nevada
 2. LOCATION S/SW 1/4 SW 1/4 Sec 15 T 17 N/S R 25 E Lyon County
 PERMIT NO. 17-394-08
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>63</u>	
<u>Clay</u>		<u>63</u>	<u>113</u>	
<u>Sand coarse</u>		<u>113</u>	<u>173</u>	
<u>Clay</u>		<u>173</u>	<u>182</u>	
<u>Gravel s</u>		<u>182</u>	<u>200</u>	

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 1/8 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>3/16</u>	<u>71</u>	<u>20</u>
<u>6 5/8</u>	<u>3.00</u>	<u>3/16</u>	<u>20</u>	<u>200</u>

Perforations:
 Type perforation Self Sw
 Size perforation 1 1/4 x 6 holes 5 Rows
 From 180 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 0-50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level: 32 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 2-20 7900
 Date completed 2-21 000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>Produced about 50 GPM</u>	<u>30</u>	<u>6 hr</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lead Drilling Inc
 Address P.O. Box 579 Silver Springs NV 89429
 Nevada contractor's license number 6031841
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 21877
 Signed William J. [Signature]
 By driller performing actual drilling on site or contractor
 Date 2-21-00

RECEIVED
 00 APR 12 AM 11:46
 STATE ENGINEER'S OFFICE