

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 19675  
Permit No. 83  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43809

1. OWNER Canyon General Improvement District ADDRESS AT WELL LOCATION Near Lockwood  
MAILING ADDRESS 501 Rue de la Blanc  
Sparks, NV 89434

2. LOCATION NE 1/4 SE 1/4 Sec. 17 T 19N N/S R 21E E Storey County  
PERMIT NO. Waiver -519-C Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<b>Boulders &amp; clay</b>		0	10	
<b>basalt</b>		10	130	120
<b>green clay</b>		130	135	5
<b>grey basalt &amp; some clay</b>		135	140	5
<b>green clay</b>		140	180	40
<b>brown clay</b>		180	320	140
<b>light br. clay</b>		320	405	85
<b>ABANDONMENT</b>				
This well was abandon by placing bentonite hole plug from 405 ft. to 10 ft from the top of the hole. Placed cement plug from 10ft. to surface of well.				
		0	405	405

8. WELL CONSTRUCTION  
Depth Drilled 405 Feet Depth Cased n/a Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>9-1/2</u> Inches	0	16
<u>6-1/8</u> Inches	16	405

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>n/a</u>				

Perforations:  
Type perforation n/a  
Size perforation n/a

From n/a feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 10  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 200 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Humboldt Drilling & Pump Co., Inc. Contractor  
Address 4675 W. Winnemucca Blvd Contractor  
Winnemucca, Nevada 89445  
Nevada contractor's license number issued by the State Contractor's Board 015234  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713  
Signed Jean Q. Tomp  
By driller performing actual drilling on-site or contractor  
Date 4/17/00

Date started 4/11/00 19\_\_\_\_  
Date completed 4/16/00 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			