

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 19676
 Permit No. 83
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43809

1. OWNER Canyon General Improvement District ADDRESS AT WELL LOCATION Near Lockwood
 MAILING ADDRESS 501 Rue de la Blanc
Sparks, NV 89434

2. LOCATION NE 1/4 SE 1/4 Sec. 17 T 19N N/S R 21E E Storey County
 PERMIT NO. Waiver -519-C
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Monitor Stock Municipal/Industrial
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders & clay		<u>0</u>	<u>10</u>	
basalt		<u>10</u>	<u>130</u>	<u>120</u>
green clay		<u>130</u>	<u>135</u>	<u>5</u>
grey basalt & some clay		<u>135</u>	<u>140</u>	<u>5</u>
green clay		<u>140</u>	<u>180</u>	<u>40</u>
brown clay		<u>180</u>	<u>320</u>	<u>140</u>
light br. clay		<u>320</u>	<u>405</u>	<u>85</u>
ABANDONMENT				
This well was abandon by				
placing bentonite hole				
plug from 405 ft. to 10				
ft from the top of the				
hole. Placed cement				
plug from 10ft. to				
surface of well.				
		<u>0</u>	<u>405</u>	<u>405</u>

8. WELL CONSTRUCTION
 Depth Drilled 405 Feet Depth Cased n/a Feet
HOLE DIAMETER (BIT SIZE)
 From To
9-1/2 Inches 0 Feet 16 Feet
6-1/8 Inches 16 Feet 405 Feet
 _____ Inches _____ Feet _____ Feet
CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>n/a</u>				

Perforations:
 Type perforation n/a
 Size perforation n/a
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 10 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 200 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc.
 Contractor
 Address 4675 W. Winnemucca Blvd
 Contractor
Winnemucca, Nevada 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
 Signed Jim A. Tomp
 By driller performing actual drilling on-site or contractor
 Date 4/17/00

Date started 4/11/00 19____
 Date completed 4/15/00 19____

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Time (Hours)	G.P.M.	Time (Hours)

RECEIVED
 APR 18 AM 11:20
 STATE ENGINEERS OFFICE