

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 79679  
 Permit No. \_\_\_\_\_  
 Basin 32

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 43811

1. OWNER Roy & Jeannie Clarno ADDRESS AT WELL LOCATION Sand Pass Road  
 MAILING ADDRESS P.O. Box 1710  
Winnemucca, NV 89445  
 2. LOCATION NE 1/4 SW 1/4 Sec. 7 T 38N N/S R 37E E Humboldt County  
 PERMIT NO. 06-311-07 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	4	
coarse sand		4	23	19
sm. gravel		23	27	4
coarse sand		27	35	8
sm. gravel		35	40	5
coarse sand		40	50	10
gravel/sand		50	65	15
fine sand		65	72	7
coarse sand		72	88	16
sm. gravel/sand		88	108	20
sand w/gravel stratas		108	148	40
sand w/clay & gravel		148	248	100
clay w/sand & gravel		248	290	42
gravel w/clay stringers	x	290	360	70
sandy clay		360	368	8

8. WELL CONSTRUCTION  
 Depth Drilled 368 Feet Depth Cased 350 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 inches 0 Feet 50 Feet  
9-1/2 inches 50 Feet 368 Feet  
 \_\_\_\_\_ inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+3	350

 Perforations:  
 Type perforation single row mill slot  
 Size perforation 1/8 x 3  
 From 290 feet to 350 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 368 feet

Date started 4/15/00, 19\_\_\_\_  
 Date completed 4/16/00, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>55</u>		<u>2 hrs.</u>

9. WATER LEVEL  
 Static water level 132 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good  
 10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Humboldt Drilling & Pump Co., Inc. Contractor  
 Address 4675 W. Winnemucca Blvd Contractor  
Winnemucca, Nevada 89445  
 Nevada contractor's license number issued by the State Contractor's Board 015234  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2140  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 4/25/00

RECEIVED  
 00 APR 27 AM 11:40  
 STATE ENGINEERING OFFICE