WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79686
Permit No.
Basin 19

NOTICE OF INTENT NO. 3[illegible]53

1. OWNER **EUGENE BUYTEN**
MAILING ADDRESS **115 N. WEST ST**
YERRINGTON, NV 89447

ADDRESS AT WELL LOCATION **SE CORNER OF COTTONWOOD DRIVE AND QUAKING ASPEN ROAD**

2. LOCATION **NW** 1/4 **SW** 1/4 Sec. **3** T **36N** N/S R **69E** E **ELKO** County
PERMIT NO. (Issued by Water Resources) **10-55A-08** (Parcel No.) **CLEARWATER ESTATES #1** (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
TOPSOIL		0	1	1
BOULDERS		1	60	59
BOULDERS, SAND & GRAVEL	100	60	120	60

Date started **02/08/2000**, 19__
Date completed **02/08/2000**, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		3

8. **WELL CONSTRUCTION**
Depth Drilled **120** Feet Depth Cased **120** Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	120 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	120

Perforations:
Type perforation **NA**
Size perforation **NA**
From **NA** feet to **NA** feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal **50**
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From **50** feet to **120** feet

9. **WATER LEVEL**
Static water level **91** feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **HACKWORTH DRILLING, INC** (Contractor)
Address **P.O.BOX 850** (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board **020582**
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1689**
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date **02/09/2000**

USE ADDITIONAL SHEETS IF NECESSARY