WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79699
Permit No.
Basin 102

NOTICE OF INTENT NO. 43627

1. OWNER COUNTRY HOMES
MAILING ADDRESS 4240 RENO HWY
FALLON, NV, NV 89406

ADDRESS AT WELL LOCATION LOT 203 6TH STREET
Silver Springs, NV

2. LOCATION NW 1/4 NE 1/4 Sec. 17 T 17 N/S R 25 E LYON County
PERMIT NO. (Issued by Water Resources) Parcel No. LOT 203 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BR SAND		0	15	15
BR CLAY		15	20	5
BR SAND		20	45	25
BR CLAY		45	80	35
BL SILT		80	90	10
BL CLAY		90	100	10
BL SILT		100	130	30
BL CLAY		130	135	5
MC GRAVELS	X	135	150	15
		150		

OCT 27 PM 12:00
STATE ENGINEER'S OFFICE

Date started 12/6/1999, 19__
Date completed 3/4/2000, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 HR

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 5/8	Inches	0	Feet	150	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	150

Perforations:
Type perforation MACHINE PERF
Size perforation .080
From 138 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed (By driller performing actual drilling on-site or contractor)
Date 3/22/2000

USE ADDITIONAL SHEETS IF NECESSARY