

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 79799
 Permit No. DW 112
 Basin 212
 41-739

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41-739

1. OWNER CAS VEGAS PAVING CORP ADDRESS AT WELL LOCATION ENCL OF E
 MAILING ADDRESS 4420 S. DECATUR SUBSET RD & CAS VEGAS WASH
CAS VEGAS, NV 89103
 2. LOCATION SW 1/4 S 1/2 Sec 30 T 21 N/S R 6S E CLARK County
 PERMIT NO. DW 9112 160-30-003 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other well points
 4. dewater PROPOSED USE Dewatering
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other well points

6. ~~1-15~~ LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>23-285 Silty Sand (sm)</u> <u>Downs, medium</u> <u>dense, Brown</u>	<u>4'</u>	<u>0</u>	<u>5</u>	<u>5'</u>
<u>2. Pochy Gravel</u> <u>Gravel w/ sand (gp)</u> <u>Medium dense</u> <u>gray to black</u>	<u>4'</u>	<u>5</u>	<u>12'</u>	<u>7'</u>
<u>3. Silty Sand (sm)</u> <u>Fine Gravel, medium</u> <u>dense, gray</u>	<u>4'</u>	<u>12</u>	<u>16'</u>	<u>4'</u>
<u>4. Pochy Gravel</u> <u>Gravel with silt</u> <u>& sand (gp-sm)</u>	<u>4'</u>	<u>16'</u>	<u>20'</u>	<u>4'</u>

8. WELL CONSTRUCTION
 Depth Drilled 20' Feet Depth Cased 12'-20' Feet
 HOLE DIAMETER (BIT SIZE)
 From 2' Inches To 20 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PL</u>	<u>sch 40</u>	<u>0</u>	<u>20</u>

Perforations:
 Type perforation Factory perf well points
 Size perforation .070
 From 60' feet to 18' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 4' feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature _____ °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Foot Hill Eng & Dewatering Contractor
 Address 905 E. Third St. Contractor
CORONA, Ca 91719
 Nevada contractor's license number issued by the State Contractor's Board 0035906
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 2119
 Signed Steve J. Smith
 By driller performing actual drilling on site or contractor
 Date 3-13-00

Date started 3-13 800
 Date completed 3-14 1000

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Pump</u>	<u>App 65</u>	<u>0</u>	<u>20 min</u>