

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 79922
 Permit No. _____
 Basin. 107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43066

1. OWNER Donald Leverty Const ADDRESS AT WELL LOCATION: 294 Jensen Smith Valley
 MAILING ADDRESS: _____
 2. LOCATION SW 1/4 SW 1/4 Sec 30 T 12 N S R 23 E County Yuan
 PERMIT NO. 00904101 Parcel No. _____ Subdivision Name Smith Valley
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RYC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Fine Sand</u>		<u>0</u>	<u>63</u>	<u>63</u>
<u>Dark Clay</u>		<u>63</u>	<u>67</u>	<u>4</u>
<u>Well Sorted Med Sand</u>		<u>67</u>	<u>88</u>	<u>21</u>
<u>Sandy Clay</u>		<u>88</u>	<u>111</u>	<u>23</u>
<u>Dark Clay</u>		<u>111</u>	<u>197</u>	<u>86</u>
<u>Sandy Clay</u>		<u>197</u>	<u>237</u>	<u>40</u>
<u>Well Sorted Med Sand</u>		<u>237</u>	<u>276</u>	<u>39</u>
<u>Dark Clay</u>		<u>276</u>	<u>280</u>	<u>4</u>

8. WELL CONSTRUCTION
 Depth Drilled 280 Feet Depth Cased 280 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 280 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>280</u>

Perforations:
 Type perforation Factory Milled
 Size perforation 1/2 x 3
 From 240 feet to 280 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 280 feet

Date started 3-21 2000
 Date completed 3-27 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air Lift</u>	<u>50</u>		<u>1 1/2</u>

9. WATER LEVEL
 Static water level 97' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Edlco Exploration Inc Contractor
 Address 7780 CURRY RD Contractor
FALLEN NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 3-27-00

RECEIVED
 00 APR 11 AM 11:21
 STATE ENGINEER'S OFFICE