

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 79940  
Permit No. 105  
Basin

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41938

1. OWNER Rick Decarlo Custom Homes ADDRESS AT WELL LOCATION 724 Marron Wy Gardnerville NV 89410  
MAILING ADDRESS P.O. Box 2844 Minden NV 89423  
2. LOCATION NW 1/4 NW 1/4 Sec. 20 T. 12 N. R. 20 E Douglas County  
PERMIT NO. 20-001-021  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>overburden</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Large Cobbles and Ballbars with small loose sands</u>		<u>3</u>	<u>78</u>	<u>75</u>
<u>Coarse Sands and cobbles</u>		<u>78</u>	<u>91</u>	<u>13</u>
<u>Brown Clay and sands</u>		<u>91</u>	<u>103</u>	<u>12</u>
<u>Brown Clay seams and small sands and Gravels</u>		<u>103</u>	<u>138</u>	<u>35</u>
<u>Large Gravels and cobbles</u>	<u>XX</u>	<u>138</u>	<u>160</u>	<u>22</u>

8. WELL CONSTRUCTION  
Depth Drilled 160 Feet Depth Cased 160 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 Feet To 160 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:  
Type perforation Mill Slot  
Size perforation 3x3/32  
From 140 feet to 160 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 100  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 100 feet to 160 feet

9. WATER LEVEL  
Static water level: 65 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. 30+ P.S.I.  
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Carson City Well Drilling Contractor  
Address 20 Kit Kat DR. Carson City NV 89706 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 41775  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
Signed William L. Hall By driller performing actual drilling on site or contractor  
Date 5-2-00

Date started 4-30-00 19.00  
Date completed 5-1-00 19.00

7. WELL TEST DATA

TEST METHOD:	<input checked="" type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>30+</u>	<u>25</u>	<u>3</u>	