WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79942
Permit No.
Basin 105

NOTICE OF INTENT NO. 43065

1. OWNER Charles N. Grant Const
MAILING ADDRESS P.O. Box 2175 Minden, Nv 89423
ADDRESS AT WELL LOCATION 1879 Colt Gardnerville, NV 89410

2. LOCATION NW ¼ SE ¼ Sec. 24 T. 12 N S R. 20 E. Douglas County
PERMIT NO. 1220-24-201-040 (Issued by Water Resources) ~~1220-2420-1040~~ (Parcel No.)
Rutenstroth Lot 27D (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☑ Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay Soil | | 0 | 21 | 21 |
| Unsorted Gravel Boulders | | 21 | 54 | 33 |
| Sandy Clay | | 54 | 76 | 22 |
| Unsorted Gravel | | 76 | 105 | 29 |
| Sandy Clay | | 105 | 112 | 7 |
| Unsorted Gravel | ✓ | 112 | 130 | 18 |
| Sorted Med Gravel | ✓ | 130 | 160 | 30 |

Date started 3-9-00
Date completed 3-15-00

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 425 | | 1 hr |

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 10 5/8 | 0 | 160 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | .188 | +2 | 160 |
| | | | | |

Perforations:
Type perforation Factory Milled
Size perforation 14 x 3 6 Row
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 71 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc (Contractor)
Address 7780 Curry Rd (Contractor)
Fallon, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-20-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627