

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43088

1. OWNER C. + P NEALS ADDRESS AT WELL LOCATION 200 CENTENNIAL GENOA  
MAILING ADDRESS Box 233 GENOA, NV 89411

2. LOCATION NE 1/4 NE 1/4 Sec 9 T 13 N/S R 19 E Douglas County  
PERMIT NO. 17 022 19 Parcel No. NA Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

| Material  | Water Strata | From | To  | Thick-ness |
|---|--------------|------|-----|------------|
| SOIL BOULDERS<br>grey, black, brown + reddish                   |              | 0    | 40  | 40         |
| BROKEN VOLCANIC ROCK<br>grey, black, brown + reddish            |              | 40   | 150 | 110        |
| BROKEN VOLCANIC ROCK<br>w/ <del>reddish</del> BROWN CLAY LAYERS |              | 150  | 200 | 50         |

8. WELL CONSTRUCTION  
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
From 10 5/8 Inches To 200 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet)  | To (Feet)  |
|--------------------|---------------------|-------------------------|--------------|------------|
| <u>6 5/8</u>       |                     | <u>.188</u>             | <u>0 + 2</u> | <u>160</u> |

Perforations:  
Type perforation FACTORY SLOT  
Size perforation 3/32  
From 160 feet to 200 feet  
From.....feet to.....feet  
From.....feet to.....feet  
From.....feet to.....feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 200 feet

9. WATER LEVEL  
Static water level 86 feet below land surface  
Artesian flow..... G.P.M..... P.S.I.  
Water temperature 55 °F Quality good

Date started 1-27 2000  
Date completed 2-4 2000

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

| G.P.M.     | Draw Down (Feet Below Static) | Time (Hours) |
|------------|-------------------------------|--------------|
| <u>40+</u> |                               | <u>3</u>     |

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name NEVADA DRILLING INC Contractor  
Address 75 LEWERS CREEK ROAD Contractor  
CARSON CITY NV 89704  
Nevada contractor's license number issued by the State Contractor's Board 13697A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902  
Signed John G. Rieck  
Driller performing actual drilling on site or contractor  
Date 3-24-00