

OFFICE USE ONLY
 Log No. 79950
 Permit No. 105
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41927

1. OWNER Manfred Stump ADDRESS AT WELL LOCATION 2655 Beaky
 MAILING ADDRESS #7 Willshire crt. Minden W. 89423
Columbia, South Carolina 29229

2. LOCATION NE 1/4 NE 1/4 Sec. 33 T. 14 S. R. 20 E. Douglas County
 PERMIT NO. 21-120-420 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Hand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Hard Pan Clay</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>Course DB Sands</u>		<u>6</u>	<u>43</u>	<u>37</u>
<u>Brown Silty Sands</u>		<u>43</u>	<u>86</u>	<u>43</u>
<u>Brown Clay zone</u>		<u>86</u>	<u>110</u>	<u>24</u>
<u>Silty Brown Sands and Clay</u>		<u>110</u>	<u>129</u>	<u>19</u>
<u>Course DB Sand and Course Gravel and Quartz and Granite</u>	<u>XX</u>	<u>129</u>	<u>160</u>	<u>31</u>

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet
 From 0 Feet To 160 Feet
 From 0 Feet To 160 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3x3/32
 From 140 feet to 160 feet
 From 160 feet to 160 feet
 From 160 feet to 160 feet
 From 160 feet to 160 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 55 feet to 160 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow G.P.M. 257 P.S.I.
 Water temperature Cold °F Quality Good

Date started 5-9, 1900
 Date completed 5-11, 1900

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>257</u>	<u>10</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 Kit Kat Dr Carson City W. 89706 Contractor
 Nevada contractor's license number 41775 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1985
 Signed [Signature] By driller performing actual drilling on site of contractor
 Date 5-11-00