REPORT NO. A00.027

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 79953
PERMIT NO.
BASIN 104

NOTICE OF INTENT NO. 43915

OWNER Gordon Hensman
MAILING ADDRESS 2310 Washington St Carson City NV 89703

ADDRESS OF WELL 2310 Washington St
Carson City NV 89703

2. WELL LOCATION N1/2 1/4 NE 1/4 SEC. 13 T 15N R 19 E Carson COUNTY

PERMIT NO DEW 24 PARCEL NO 07-282-21 SUBDIVISION NAME Carson City

3. TYPE OF WOR
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USI [X] Dewater
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LC

MATERIAL	STRATA	FROM	TO	THICKNESS
Dirt		0	10	10
DG		10	60	50
DG & sand	X	60	70	10
DG		70	80	10

Notes :

Date Started 4-24-00 Date Completed 4-25-00

7. WELL TEST DAT

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		1 1/2 hr

8. WELL CONSTRUCTIOI

Depth Drilled 79 Depth Cased 79

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 10 Feet
8 1/2 Inches 10 Feet 79 Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+1	79

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From Feet to Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 10
SEAL TYPE: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
PLACEMENT METHOD: [ ] Pumped [X] Poured

GRAVEL PACKED: [X] Yes [ ] No
From 10 Feet to 79 Feet

9. WATER LEVE
Static Water Level 44' Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATIO
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1981
Signed [signature]
By driller performing actual drilling on site or contractor
Dated May 8 - 00