

OFFICE USE ONLY
 Log No. 79976
 Permit No. 923
 Basin 923

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43862

1. OWNER JOE REICHLIN ADDRESS AT WELL LOCATION 107 Heindel Road
 MAILING ADDRESS 15650 Toll Road Reno, Nevada 89506
Reno, Nevada 89511

2. LOCATION NE 1/4 NW 1/4 Sec. 16 T. 20N N/S R. 19 E Washoe County
Black Springs Area
 PERMIT NO. 082-262-03 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown clay with some boulders & gravels		1	8	7
Brown clay		8	22	14
Brown sandy clay		22	69	47
Soft zone (NO WATER)		69	70	1
Brown sandy clay		70	92	22
Soft zone (NO WATER)		92	94	2
Brown sandy clay some gravel		94	184	90
Weathered granite with white clay		184	192	8
Brown sandy clay		192	231	39
Soft zone (app 5 GPM)	X	231	239	8
Weathered granite with clay streaks		239	287	48
Fracture soft (app 5 GPM)	X	287	305	18
Weathered granite		305	324	19
White clay		324	325	1

8. WELL CONSTRUCTION
 Depth Drilled 325 Feet Depth Cased 325 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 100 Feet
8 5/8 Inches 100 Feet 325 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	325

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around

From 240 feet to 260 feet
 From 280 feet to 320 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 foot Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 325 feet

Date started April 11, 2000
 Date completed April 12, 2000

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		

9. WATER LEVEL
 Static water level 150 feet below land surface
 Artesian flow _____ G.P.M. 10 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 923

Signed Edward [Signature]
 By driller performing actual drilling on site or contractor
 Date April 14, 2000