

OFFICE USE ONLY
 Log No. 80013
 Permit No. _____
 Basin 162

 NOTICE OF INTENT NO. 20192

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER PALM HARBOR VILLAGE ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ 5210 S. BATDORF CT.
 2. LOCATION NE 1/4 NE 1/4 Sec. 7 T 21-S N/S R 54 E NYE County _____
 PERMIT NO. _____ 45-083-29 PARCEL 4
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE		0	4	4
BROWN CLAY		4	37	33
GRAY CLAY/CALICHE		37	68	31
BROWN CLAY	X	68	88	20
BROWN CLAY/CALICHE		88	123	35
BROWN CLAY		123	134	11
BROWN CLAY/CALICHE	X	134	160	26

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	160

Perforations:
 Type perforation TORCH CUT
 Size perforation 1/4" WIDTH 8" LONG
 From 120 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 60' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started JUNE 8, 2000
 Date completed JUNE 8, 2000

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name JIM PIKE WELL DRILLING, LLC. Contractor
 Address P.O. BOX 56 Contractor
PAHRUMP, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 17563A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date JUNE 12, 2000