



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19489

1. OWNER Harold E. Launsbury ADDRESS AT WELL LOCATION 14580 KYLE CANYON RD
MAILING ADDRESS HCR 38 Box 180 Las Vegas, Nev. 89124-9107 Same
2. LOCATION SE 1/4 NW 1/4 Sec 18 T 19S N/S R 59 E Clark County
PERMIT NO. 126-48-201-001 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Cemented Gravel		0	6	
Gravel		6	50	
Limestone Grey		50	85	
" Lt. Brown		85	100	
" Yellowish		100	130	
" Cream		130	145	
" Grey		145	155	
" Yellow		155	190	
" Grey		190	195	
" Yellow		195	200	
" Brown		200	205	
" Cream		205	230	
" Greenish		230	250	
" Yellow		250	265	
" Brown		265	325	
" Yellow		325	340	
" Bright Yellow		340	355	
" Grey		355	505	
" Charcoal		505	520	
" Yellow		520	550	
" Grey & Water	xz	550	555	
" Grey		555	565	
Very Hard		565	580	
Grey & Water	zzx	580	595	
" Grey		595	640	
" Grey & Water	xx	640	655	
" Grey		655	700	
" Gractured & Water	xx	700	745	

8. WELL CONSTRUCTION
Depth Drilled 745 Feet Depth Cased 745 Feet

HOLE DIAMETER (BIT SIZE)
From To
12 1/4 Inches 0 Feet 55 Feet
8 3/4 Inches 55 Feet 745 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+1	745
5 1/2	SRD21	PVC	+1	745

Perforations:
Type perforation Factory
Size perforation Sieve Type
From 600 feet to 620 feet
From 700 feet to 720 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal: _____
Placement Method: Pumped
 Poured
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 540 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick Contractor
Address 5360 Bonita Vista Contractor
Las Vegas, Nev. 89149

Nevada contractor's license number 10062 issued by the State Contractor's Board.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552

Signed VH Dimick
By driller performing actual drilling on site or contractor
Date 6-1-00

Date started 4-10-00 19__
Date completed 4-19-00 19__

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

