TE—DIVISION OF WATER RESOURCES
RY—CLIENT'S COPY
—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80086
Permit No.
Basin 216

NOTICE OF INTENT NO. 19733

1. OWNER DRY LAKE WATER COMPANY
MAILING ADDRESS 3320 N. BUFFALO, STE. 207
LAS VEGAS, NV 89129

ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ SE ¼ Sec. 21 T. 17 N/S R. 63 E. CLARK County
PERMIT NO. W-2088 (Issued by Water Resources) | 084-21-000-001 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & GRAVEL		0	10	10
CEMENTED GRAVEL		10	260	250
LIMESTONE		260	500	240
CEMENTED GRAVEL		500	570	70
LIMESTONE		570	620	50
CEMENTED GRAVEL		620	640	20
LIMESTONE	880	640	890	250
LIMESTONE WITH STREAKS OF CEMENTED GRAVEL		890	1050	160
NO RETURNS		1050	1509	459
GREY LIMESTONE	X	1509	1736	227
DARK GREY TO BLACK LIMESTONE W/FRACTURES	X	1736	2130	394
THICKLY BEDDED LIMESTONE AND SHALE	X	2130	2480	350

Date started 1/27/00, XX
Date completed 6/20/00, XX

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
450 HP PUMP	300	1000	336

8. WELL CONSTRUCTION
Depth Drilled 2480 Feet Depth Cased 1434 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
17.5 Inches		0 Feet	1434 Feet
10 3/4 Inches		1440 Feet	1504 Feet
7 7/8 Inches		1504 Feet	2480 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	33.4	.250	+2	1434
20	52.7	.250	0	12

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 1440 feet

9. WATER LEVEL
Static water level 882 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WATER WELL SERVICES (Contractor)
Address 6475 GARY AVE. (Contractor)
LAS VEGAS, NV 89139
Nevada contractor's license number issued by the State Contractor's Board 22311B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594/1426
Signed (By driller performing actual drilling on site or contractor)
Date 6/20/00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627