

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19084

1. OWNER Jason Houser ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3851 Tumbleweed Ave. 3851 Tumbleweed Ave.  
Pahrump, Nevada 89048  
 2. LOCATION SE 1/4 SE 1/4 Sec. 32 T. 20 N. R. 53 E Nye County  
 PERMIT NO. 40-601-06 Calvada Valley Unit 5 Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0'	5'	5'
white clay		5'	10'	5'
caliche		10'	15'	5'
white clay		15'	40'	25'
brown clay		40'	65'	25'
caliche		65'	70'	5'
brown clay		70'	95'	25'
white clay		95'	120'	25'
caliche		120'	125'	5'
brown clay		125'	140'	15'

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0	140

Perforations:  
 Type perforation Saw cut  
 Size perforation 1/8" x 3"  
 From 100 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 140' feet

9. WATER LEVEL  
 Static water level 50 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge. **I**  
 Name Larue Construction Co. Contractor  
 Address 4191 S. Jackie St. Pahrump, Nevada 89048 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0049225  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116  
 Signed Forest Larue  
 By driller performing actual drilling on site or contractor  
 Date June 19, 2000

Date started May 19 2000  
 Date completed May 25 2000

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)