WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80096
Permit No.
Basin 212

NOTICE OF INTENT NO. 18549

1. OWNER Agra Earth & Environmental
MAILING ADDRESS 4205 West Tompkins Avenue, Suite 5
Las Vegas, NV 89103

ADDRESS AT WELL LOCATION 1921 North Lamb Blvd
(just south of Lake Mead Blvd), Clark County, NV

2. LOCATION NW 1/4 SW 1/4 Sec. 20 T 20S N/S R 62E E Clark County
PERMIT NO. (Issued by Water Resources) 140-20-301-006 (Parcel No.) B-2 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt		0	4	4
Silty Lean Clay		4	6	2
Silty Gravel		6	7	1
Clayey Silt		7	9	2
Lean Clay		9	20	11
Silty Sand		20	25	5
Sandy Silt		25	26	1
Silty Sand		26	27	1
Lean Clay		27	30	3
Silty Sand		30	36	6
Poorly Graded Sand		36	38	2
Clayey Sand		38	40	2

Date started 4/20/2000 , 19__
Date completed 4/20/2000 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 in	Inches	0	Feet	40	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	40

Perforations:
Type perforation factory slot PVC
Size perforation 0.20
From 20 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0-5ft, 5-10ft benton
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 15 feet to 40 feet

9. WATER LEVEL
Static water level None measured feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Don Wilson c/o Converse Consultants (Contractor)
Address 731 Pilot Road, Suite H (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed (By driller performing actual drilling on-site or contractor)
Date 6/9/2000

USE ADDITIONAL SHEETS IF NECESSARY