WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80098
Permit No.
Basin 212

NOTICE OF INTENT NO. 18545

1. OWNER Nevada Dept of Agriculture
MAILING ADDRESS 350 Capitol Hill Avenue
Reno, NV 89502

ADDRESS AT WELL LOCATION 5692 Boulder Highway,
Las Vegas, Nevada (NEC of Boulder Highway and Russell Road)

2. LOCATION NE 1/4 NE 1/4 Sec. 34 T 21S N/S R 62E E Clark County
PERMIT NO. (Issued by Water Resources) 161-34-502-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Loam		0	4	4
Gravelly Loam		4	9	5
Gravelly Sand		9	14	5
Silty Sand		14	18	4
Fat Clay		18	24	6

Date started 5/11/2000, 19__
Date completed 5/11/2000, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 24 Feet Depth Cased 24 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	24	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.70	0.154	0	24

Perforations:
Type perforation Factory slotted PVC
Size perforation 0.020 inch
From 19 feet to 24 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0-11'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 14 feet to 24 feet

9. WATER LEVEL
Static water level 9.5 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature 77 °F Quality 3,610 mg/L TDS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Tom High c/o Converse Consultants (Contractor)
Address 731 Pilot Road, Suite H (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1869
Signed (By driller performing actual drilling on-site or contractor)
Date 6/16/2000

USE ADDITIONAL SHEETS IF NECESSARY