

OFFICE USE ONLY  
 Log No. 80115  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20442

1. OWNER Contri Const ADDRESS AT WELL LOCATION ARLINGTON & COLORADO WEST TO 95  
 MAILING ADDRESS P.O. Box 97739 Las Vegas NV 89193  
 2. LOCATION 1/4 Sec. 4 & 5 T. 21 N. R. 62 E. CLARK County  
 PERMIT NO. DW 116 161-04-219-000 Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. ~~Water~~ PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Clay</u>		<u>0</u>	<u>6</u>	
<u>Clay fine sand mix</u>		<u>6</u>	<u>15</u>	
<u>Clay</u>		<u>15</u>	<u>20</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 20 Feet Depth Cased 20 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 24 Inches 0 Feet 20 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12"</u>	<u>PVC</u>	<u>SL. 40</u>	<u>0</u>	<u>20</u>

Perforations:  
 Type perforation Slot  
 Size perforation .032  
 From 0 feet to 20 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No #5  
 From 0 feet to 20 feet

9. WATER LEVEL  
 Static water level 6 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 72 °F Quality Good

Date started 6-1-1900  
 Date completed 6-1-1900

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GRIPIN DEWATERING  
 Address 500 E. MATTIAND  
Ontario Cal 91761  
 Nevada contractor's license number 0031246  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS-2150  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 6-1-00