

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41139

1. OWNER CAS VEGAS PAVING ADDRESS AT WELL LOCATION END OF E. SUSET RD + CAS VEGAS WASH  
 MAILING ADDRESS 4420 S. DECATOR RD + CAS VEGAS NV 89103  
 2. LOCATION SW 1/2 S 1/2 Sec. 30 T. 21 N/S R. 63 E. CLARK County  
 PERMIT NO. DW 1112 Issued by Water Resources Parcel No. 160-30-003 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other Wellpoint  
 4. Dewater PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other Wellpoints

6. ~~114-170~~ LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
1. <u>Silty Sand w/Gravel (SM) dense, light Brown</u>	<u>4'</u>	<u>0'</u>	<u>3'</u>	<u>3'</u>
2. <u>CLAYEY Sand w/Gravel (SC) medium dense, Brown</u>	<u>4'</u>	<u>3'</u>	<u>13'</u>	<u>10'</u>
3. <u>Poorly Graded Sand w/silt &amp; Gravel (SP-SM) Very Large Cobbles</u>	<u>4'</u>	<u>13'</u>	<u>20'</u>	<u>7'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 20' Feet Depth Cased 17'-20' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 2 Inches To 20' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PUL</u>	<u>Sch 40</u>	<u>Wellpoints</u>	<u>0-20</u>

Perforations:  
 Type perforation FACTORY PERF wellpoint  
 Size perforation 20" - 670  
 From 20' feet to 18' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 4' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality Good

Date started 3-6-00  
 Date completed 3-6-00

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>65</u>	<u>5</u>	<u>20 MIN</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FOOTHILL ENGR & DEWATERING  
 Address 905 E. THIRD ST COCONA, CA 91719  
 Nevada contractor's license number issued by the State Contractor's Board 0035906  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2119  
 Signed [Signature]  
 Date 3-6-00