

usc

WHITE - DIVISION OF WATER RESOURCES  
CANARY - CLIENT'S COPY  
PINK - WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 80216

Permit No. \_\_\_\_\_

Basin 162

NOTICE OF INTENT NO. 20341

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Dean & Doris Hughes ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 4391 W. Maple Road 4391 W. Maple  
Pahrump, NV 89048

2. LOCATION NW 1/4 SE 1/4 Sec. 23 T 20S N/S R 52E E Nye County  
 PERMIT NO. 28-811-04 Charleston Park  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

New Well  Replace  Recondition  Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Deepen  Abandon  Other  Municipal/Industrial  Monitor  Stock  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown clay		0	2	2
grey clay		2	12	10
grey caleche		12	16	4
grey clay	x	16	55	39
grey caleche	x	55	58	3
light green caleche	x	58	75	17
grey caleche	x	75	78	3
brown clay	x	78	105	27
See next line	x	105	140	35
grey clay with caleche strings				

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140+1 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>11</u>	<u>0</u>	<u>140</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation sawcut  
 Size perforation .188

From	To	feet to	feet
<u>125</u>	<u>140</u>		

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL

Static water level 54 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor  
 Address 2301 Winery Road, Suite 2 Contractor  
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed Lacey Strickland  
 By driller performing actual drilling on-site or contractor  
 Date 5-23-00

Date started 4/10/00 19\_\_  
 Date completed 4/10/00 19\_\_

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

