

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. **80217**
 Permit No. _____
 Basin **162**

NOTICE OF INTENT NO. **20342**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **Joe & Belinda Thompson** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **4491 E. Navajo** **4491 E. Navajo**
Pahrump, NV 89048

2. LOCATION **SE 1/4 NE 1/4 Sec. 20 T 21S** N/S R **54** E **Nye** County
 PERMIT NO. **45-282-01** **Green Saddle Ranch**
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown clay		0		
brown silt		0	12	12
brown clay with silt		12	38	26
See next line	x	38	140	102
brown clay with calech strings				

8. WELL CONSTRUCTION

Depth Drilled **140** Feet Depth Cased **140+1** Feet

HOLE DIAMETER (BIT SIZE)

From	To
11 Inches	0 Feet 140 Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140
_____	_____	_____	_____	_____

Perforations:

Type perforation **sawcut**
 Size perforation **.188**

From **125** feet to **140** feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **140** feet

9. WATER LEVEL

Static water level **59** feet below land surface
 Artesian flow **59** G.P.M. _____ P.S.I.
 Water temperature **cool** °F Quality **good**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *[Signature]* By driller performing actual drilling on-site or contractor
 Date **4.27.00**

Date started **4/27/00**, 19____
 Date completed **4/27/00**, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift
 Draw Down (Feet Below Static) Time (Hours)

G.P.M.	Time (Hours)
_____	_____
_____	_____

