

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **80224**
 Permit No. _____
 Basin **162**
 NOTICE OF INTENT NO. **20350**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **Ron Murphy** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **331 N. Murphy** **331 N. Murphy**
Pahrump, NV 89048

2. LOCATION **SE 1/4 SE 1/4 Sec. 12 T 20S** N/S **R 52** E **Nye** County
 PERMIT NO. **28-841-03** **Douglas M. Hafen**
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other Municipal/Industrial Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	5	5
grey clay		5	12	7
brown clay		12	29	17
brown caleche		29	34	5
grey clay		34	44	10
brown clay	x	44	62	18
brown clay with caleche	x	62	140	78

8. WELL CONSTRUCTION

Depth Drilled **140** Feet Depth Cased **140+1** Feet

HOLE DIAMETER (BIT SIZE)

From **11** Inches To **0** Feet **140** Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation **sawcut**
 Size perforation **.188**

From **125** feet to **140** feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal **50** Cement Grout
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **140** feet

Date started **4/21/00**, 19__
 Date completed **4/21/00**, 19__

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	

9. WATER LEVEL

Static water level **57** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cool** °F Quality **good**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *[Signature]* By driller performing actual drilling on-site of contractor
 Date **4-25-00**