WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80228
Permit No.
Basin 162

NOTICE OF INTENT NO. 20343

1. OWNER Nationwide Homes
MAILING ADDRESS 3301 W. Shadow Mountain
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
3301 W. Shadow Mountain

2. LOCATION NW 1/4 SE 1/4 Sec. 1 T 20S N/S R 52E E Nye County
PERMIT NO. Issued by Water Resources | 28-422-07 Parcel No. | Vegas Acres Subdivision Name

3. WORK PERFORMED
X New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	17	17
See next line		17	25	8
brown clay with caleche strings				
brown loam		25	38	13
See next line		38	46	8
brown loam with grey caleche strings				
See next line	x	46	78	32
grey loam with caleche strings				
See next line	x	78	96	18
brown loam with caleche strings				
brown loam	x	96	140	44

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140+1 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
Type perforation sawcut
Size perforation .188
From 125 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the ~~on-site driller~~ 2086
Signed Larry Strickland By driller performing actual drilling on-site or contractor
Date 5·23·00

Date started 4/13/00 , 19__
Date completed 4/13/00 , 19__

7. WELL TEST DATA
TEST METHOD: Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

JUN 7 2000
LAS VEGAS OFFICE