WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80233
Permit No.
Basin 162

NOTICE OF INTENT NO. 20360

1. OWNER Elroy Strickland
MAILING ADDRESS 4320 W. Elvira
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
4320 W. Elvira

2. LOCATION NE 1/4 NE 1/4 Sec. 26 T 20S N/S R 52E E Nye County
PERMIT NO. Issued by Water Resources | 28-601-23 Parcel No. | Vegas Acres Subdivision Name

3. WORK PERFORMED
X New Well, Replace, Recondition, Deepen, Abandon, Other

4. PROPOSED USE
X Domestic, Irrigation, Test, Municipal/Industrial, Monitor, Stock

5. WELL TYPE
Cable, X Rotary, RVC, Air, Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	22	22
See next line		22	45	23
grey clay with caleche stringers				
light green clay	x	45	68	23
See next line	x	68	140	72
grey clay with caleche stringers				

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140+1 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
Type perforation sawcut
Size perforation .188
From 125 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: X Yes No
Depth of Seal 50
Placement Method: Pumped, X Poured
Seal Type: Neat Cement, Cement Grout, X Concrete Grout

Gravel Packed: X Yes No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 62 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Larry Strickland By driller performing actual drilling on-site or contractor
Date 6-3-00

Date started 5/15/00 , 19__
Date completed 5/15/00 , 19__

7. WELL TEST DATA
TEST METHOD: Bailer Pump Air Lift
G.P.M. Draw Down (Feet Below Static) Time (Hours)

CONFIDENTIAL RECEIVED JUN 7 2000