WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80238
Permit No.
Basin 162

NOTICE OF INTENT NO. 19161

1. OWNER Bob Funk
MAILING ADDRESS 4490 Red Hawk Ct. Pahrump, Nevada 89048
ADDRESS AT WELL LOCATION 4490 Red Hawk Ct. Pahrump, NV

2. LOCATION NE ¼ SE ¼ Sec. 24 T. 19 N/S R. 52 E/W Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. 27-732-62 Nye County (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt		0	10'	10'
white clay		10'	15'	5'
caliche		15'	20'	5'
brown clay		20'	50'	30'
brown caliche		50'	55'	5'
brown caliche		55'	70'	15'
white clay		70'	80'	10'
brown clay		80'	105'	25'
brown caliche		105'	110'	5'
brown clay		110'	135'	25'
caliche		135'	140'	5'
brown clay		140'	160'	20'

Date started June 17, 2000
Date completed June 20, 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0'	160'

Perforations:
Type perforation Saw cut
Size perforation 1/8" x 3"
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 160' feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LaRue Construction Co. (Contractor)
Address 4191 S. Jackie St. (Contractor)
Pahrump, Nevada 89048
Nevada contractor's license number issued by the State Contractor's Board 0049225
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest LaRue (By driller performing actual drilling on site or contractor)
Date June 23, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627