

OFFICE USE ONLY
 Log No. 80268
 Permit No. 25821
 Basin. 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18929

1. OWNER Mel & Marilyn Larson ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 13,000 S. Las Vegas Blvd 13,050 S. LV Blvd
Las Vegas, NV 89124

2. LOCATION SW 1/4 SE 1/4 Sec. 17 T. 23 N/S R. 61 E Clark County
 PERMIT NO. 25821 191-17-801-005
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & boulders		0	80	80
Brown clay		80	120	40
Sand & gravel		120	220	100
Sand & gravel		220	320	100
Sand		320	325	5
Sand & gravel		325	380	75
Grey limestone		380	580	200
Pink limestone		580	720	140
Grey shale		720	765	45
Brown sand		765	770	5
Grey shale		770	800	30

8. WELL CONSTRUCTION
 Depth Drilled 800 Feet Depth Cased 800 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches 0 Feet 540 Feet
 To 11 Inches 540 Feet 800 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>		<u>.188</u>	<u>+1</u>	<u>800</u>

Perforations: Mill slot
 Type perforation _____
 Size perforation 1/8 x 2
 From 520 feet to 600 feet
 From 680 feet to 700 feet
 From 720 feet to 740 feet
 From 760 feet to 780 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 407 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 6/18/00, 19_____
 Date completed 7/7/00, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Thompson Drilling Co., Inc.
7227 Hauck Street
 Address _____ Contractor
Las Vegas, NV 89118
 Nevada contractor's license number issued by the State Contractor's Board 4286A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2120
 Signed Richard R. Thompson
 By driller performing actual drilling on site or contractor
 Date July 14, 2000