

W.C.

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 80287
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16563

1. OWNER Ronald Stuard ADDRESS AT WELL LOCATION Star Haven
MAILING ADDRESS Las Vegas, Nev. 11450 HAVEN ST. LV.
2. LOCATION NE 1/4 NW 1/4 Sec 4 T 23 N/S R 61 E Clark County
PERMIT NO. 191-04-104-003 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED: New Well, Replace, Recondition, Deepen, Abandon, Other
4. PROPOSED USE: Domestic, Municipal/Industrial, Irrigation, Monitor, Stock, Test, Other
5. WELL TYPE: Cable, Rotary, RVC, Air, Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------------|--------------|------|-----|------------|
| Sand Gravel Boulder | | 0 | 150 | |
| Brown Clay | | 250 | 160 | |
| Red Sandstone | 5 | 260 | 375 | |
| Red Sandstone | 30 | 375 | 465 | |

8. WELL CONSTRUCTION
Depth Drilled 465 Feet Depth Cased 460 Feet
HOLE DIAMETER (BIT SIZE)
From 10" To 0 Feet 465 Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
6 5/8 480 PUL +1 460
8 5/8 188 +1 5

Perforations:
Type perforation Saw
Size perforation 1 7/8 x 8 x 3
From 380 feet to 460 feet
Surface Seal: Yes No Seal Type: Neat Cement, Cement Grout, Concrete Grout
Depth of Seal 50
Placement Method: Pumped, Poured
Gravel Packed: Yes No
From 50 feet to 460 feet

9. WATER LEVEL
Static water level 300 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 60.0 °F Quality Good

Date started 6-26 2000, 19____
Date completed 6-28 2000, 19____

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|-----------|-------------------------------|---------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>30</u> | | <u>30 min</u> |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Redding Drilling Contractor
Address 3955 Blue Diamond Rd #4 Contractor
LV NV 89139
Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1798
Signed [Signature]
By driller performing actual drilling on site of contractor
Date 6-28-00