

Log No. 80396  
 Permit No. \_\_\_\_\_  
 Basin 91

PRINT OR TYPE ONLY  
 NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31929

1. OWNER BOOMTOWN HOTEL/CASINO ADDRESS AT WELL LOCATION 31675 FT WEST OF EXIT # 4  
 MAILING ADDRESS P.O. BOX 399 VERDI, NV 89439 SOUTH SIDE OF HIGHWAY  
 2. LOCATION NE 1/4 SE 1/4 Sec 17 T 19 N/S R 18 E WASHOE County \_\_\_\_\_  
 PERMIT NO. 6500-N-523 38-120-03 Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  Abandon  Other \_\_\_\_\_  
 Deepen  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  Monitor  Stock  
 Municipal/Industrial

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>SEE ATTACHED LOG</u>				
<u>RECEIVED</u>				
<u>00 MAY 17 AM 11:48</u>				
<u>STATE ENGINEER'S OFFICE</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 670 Feet Depth Cased 0 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 670 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>NA</u>				

Perforations:  
 Type perforation NA  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 670  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 1/13/2000, 19\_\_\_\_\_  
 Date completed 2/25/2000, 19\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>WATER SAMPLES ONLY</u>		
<u>ABANDONED 4/18/2000</u>		

9. WATER LEVEL  
 Static water level SURFACE feet below land surface  
 Artesian flow 2 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature WARM °F Quality POOR

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name SARGENT IRRIGATION CO Contractor  
 Address 9955 N. VIRGINIA ST  
RENO, NV 89506 Contractor  
 Nevada contractor's license number 0021246  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources 413  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 5/10/2000