

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE
 Log No. 80905
 Permit No. 8
 Basin 8
 NOTICE OF INTENT NO. 4386

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER BYRON WHOOLEY ADDRESS AT WELL LOCATION 755 Lauden Ct.
 MAILING ADDRESS 10270 Crocket Drive Sparks, Nevada 89436
Reno, Nevada 89506
 2. LOCATION NE 1/4 NE 1/4 Sec. 13 T. 21 N N/S R. 20 E Washoe County
 PERMIT NO. 076-360-50 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
Brown clay with decomposed granite		2	5	3
Decomposed sands		5	11	6
Weathered granite with clay streaks		11	79	68
Weathered granite		79	141	62
White granite, some weathered streaks		141	231	152
Weathered granite		231	296	65
Gray granite		296	331	35
White hard granite		331	428	97
Fracture rock	X	428	433	5
White hard granite		433	451	18
Fracture rock, weathered	X	451	453	2
White hard granite		453	479	26

8. WELL CONSTRUCTION
 Depth Drilled 479 Feet Depth Cased 479 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 479 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	479

Perforations: factory sawed slot
 Type perforation.....
 Size perforation 3/32 x 3 x 5 around
 From 434 feet to 474 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 foot Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 479 feet

9. WATER LEVEL
 Static water level 415 feet below land surface
 Artesian flow..... G.P.M. 17 P.S.I.
 Water temperature cold °F Quality clear

Date started June 27, 2000 XX
 Date completed June 29, 2000 XX

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>17</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date June 30, 2000