

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 80411
 Permit No. 101
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44229

1. OWNER Wheeling Corrugating Co/ Bob Hammon ADDRESS AT WELL LOCATION 8090 Woolery Way Fallon
 MAILING ADDRESS 1134 Market St. Nv.89406
Wheeling, WV 26003
 2. LOCATION NE 1/4 SE 1/4 Sec. 14 T 19 N/S R 27 E Churchill County
 PERMIT NO. 65649 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Stock Municipal/Industrial Monitor
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	15	15
Brown Clay		15	22	7
Brown Sand		22	38	16
Gray Clay		38	56	18
Brown Clay		56	60	4
Brown Sand		60	65	5
Gray Clay		65	93	28
Brown Clay		93	95	2
Brown Sand		95	110	15
Brown Clay		110	115	5
Gray Sand		115	123	8
Gray Clay		123	125	2
Gray Sand		125	145	20
Gray Clay		145	147	2
Gray Sand		147	160	13
Brown Sand		160	187	27

8. WELL CONSTRUCTION
 Depth Drilled 187 Feet Depth Cased 187 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 187 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>14.96</u>	<u>.188</u>	<u>0</u>	<u>187</u>

Perforations:
 Type perforation Mill Cut
 Size perforation 1/8
 From 177 feet to 187 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: _____
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 187 feet

9. WATER LEVEL
 Static water level 27 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1264 Contractor
Fallon Nv. 89407
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
 Signed Wayne Parsons
 By driller performing actual drilling on-site or contractor
 Date 05/23/2000

Date started 05/18/2000, 19____
 Date completed 05/18/2000, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>100</u>		<u>1 hr</u>	